

Bremerton Fire Department

Fire Marshal's Office

TENT/CANOPY SAFETY CHECK LIST

1. All extension cords must be of sufficient size to handle any applied electrical loads. *(Typically at least 12ga)*
2. Every site must have at least one 2A10BC fire extinguisher. A class K fire extinguisher is required if deep fat frying.
3. All cooking sites must have a flame proof label on the tent/canopy.
4. All tent/canopies securely fasten to the ground or other support that will not affect escape if needed.
5. No more than 10 gallons of LPG may be kept at any one site. All containers are considered full.
6. Tents larger than 400 square feet or closer than 12' to other tents, buildings or the like, are required to have a tent permit or if part of an approved City Event a VENDOR permit is required.
7. All sites are subject to inspections and may be asked to cease operations until safety concerns are addressed.
8. The Fire Marshal reserves the right to add or modify requirements as needed to ensure the safety of everyone involved.

Please sign below for acknowledgment of the above conditions and retain this list on site for review as needed.

X _____

Sign

Date

For Questions contact Capt. Mike Six: michael.six@ci.bremerton.wa.us

